



**M.R.I. Under Water Specialists, Inc.**



**17891 Wetstone Rd.**

**North Fort Myers, Fl. 33917**

**239-707-5034 cell**

**239-236-1234 fax**

May 11, 2016

Mediterra North & South CDD  
Cleo Crismond  
Assistant Regional Manager  
Wrathell, Hunt & Associates, LLC  
9220 Bonita Beach Road Suite #214  
Bonita Springs, FL 34135

Re: Mediterra North and South

## **Inspection Summary Report**

Please see the report that we have provided to you on our inspection on curb inlets, junction boxes, head walls, as well as lake intake pipes. We have noted on the report the percentages of sand and debris that we found in each, and we recommend cleaning on all that are 25% and more with sand and debris.

Note that box 87 lake 31 on the report say 100 machine. That means that it is 100% blocked and we will need a machine to dig it out.

If you have any further questions please give us a call.

Thank you,

Mike Radford  
M.R.I. UnderWater Specialists Inc.

17891 Wetstone Rd.  
North Ft. Myers, Fl. 33917  
239-707-5034  
Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
1	L 1	40	YES
2	L 1	40	YES
229	L 1	10	
236	L 1	CLEAN	NO
236A	L 1	10	NO
237	L 1	70	YES
245	L 1	10	NO
245A	L 1	10	NO
229A	L 1 B	10	NO
228	L 1 B	CLEAN	NO
238	L 2	30	YES
239	L 2	50	YES
240A	L 2	60	YES
240	L 3	60	YES
241	L 3	60	YES
148	L 5	10	NO
149	L 5	35	YES
150	L 5	100	YES
232	L 5	25	YES
233	L 5	CLEAN	NO
234	L 5	CLEAN	NO
235	L 5	CLEAN	NO
147A	L 5	CLEAN	NO
147B	L 5	CLEAN	NO
150A	L 5	CLEAN	NO
150B	L 5	CLEAN	NO
246	L 6	5	NO
246A	L 6	5	NO
3	L 7	10	NO
4	L 7	10	NO
5	L 7	10	NO
6	L 7	50	YES
7	L 7	20	NO
35	L 8	CLEAN	NO

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
200	L 9	60	YES
201	L 9	10	NO
202	L 9	CLEAN	NO
203	L 9	CLEAN	NO
193	L 10	10	NO
194	L 10	10	NO
196	L 10	10	NO
208	L 11	20	NO
209	L 11	10	NO
210	L 11	CLEAN	NO
215	L 11	CLEAN	NO
223	L 11	40	YES
226	L 11	CLEAN	NO
227	L 11	CLEAN	NO
230	L 11	CLEAN	NO
231	L 11	20	NO
230A	L 11	CLEAN	NO
224	L 11 B	CLEAN	NO
225	L 11 B	CLEAN	NO
219	L 12	40	YES
220	L 12	18	NO
217	L 13	10	NO
218	L 13	CLEAN	NO
212	L 14	CLEAN	NO
213	L 14	10	NO
32	L 17	35	YES
33	L 17	30	YES
34	L 17	10	NO
36	L 17	60	YES

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
78	L 20	20	NO
79	L 20	10	NO
40	L 22	5	NO
40A	L 22	CLEAN	NO
37	L 23	30	YES
38	L 23	25	YES
39	L 23	5	NO
38A	L 23	20	NO
39A	L 23	10	NO
63	L 24	CLEAN	NO
64	L 24	CLEAN	NO
60	L 25	CLEAN	NO
61	L 25	CLEAN	NO
62	L 25	CLEAN	NO
65	L 25	CLEAN	NO
66	L 25	CLEAN	NO
68	L 25	5	NO
68A	L 25	CLEAN	NO
69	L 26	35	YES
71	L 26	CLEAN	NO
68B	L 26	CLEAN	NO
72	L 27 L 28	CLEAN	NO
73	L 27 L 28	10	NO
75	L 27 L 28	35	YES
76	L 27 L 28	40	YES
77	L 27 L 28	20	NO
74	L 29	10	NO
80	L 30	5	NO
81	L 30	5	NO
82	L 30	10	NO
83	L 30	CLEAN	NO
84	L 30	CLEAN	NO

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
85	L 31	CLEAN	NO
86	L 31	CLEAN	NO
87	L 31	100 MACHINE	YES
88	L 31	20	NO
89	L 32	CLEAN	NO
90	L 32	30	NO
91	L 32	CLEAN	NO
93	L 32	25	YES
94	L 32	90	YES
91A	L 32	CLEAN	NO
96	L 33	CLEAN	
98A	L 33	35	YES
95	L 34	10	NO
101	L 35	50	YES
102	L 35	10	NO
103	L 35	10	NO
104	L 36	60	YES
105	L 36	90	YES
108	L 37	5	
109	L 37	30	YES
110	L 37	10	NO
111	L 37	5	NO
112	L 37	5	NO
113	L 37	40	YES
114	L 37	40	YES
106	L 38	30	YES
107	L 38	10	NO
127	L 38	CLEAN	NO
128	L 38	10	NO
129	L 38	CLEAN	NO
130	L 38	CLEAN	NO
116	L 39	10	NO

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
117	L 39	CLEAN	NO
118	L 39	5	NO
125	L 39	10	NO
126	L 39	CLEAN	NO
197	L 40	5	NO
198	L 40	CLEAN	NO
199	L 40	10	NO
132	L 41	5	NO
133	L 41	5	NO
134	L 41	CLEAN	NO
135	L 41	CLEAN	NO
133A	L 41	5	NO
136	L 42	5	NO
137	L 42	5	NO
141	L 42	30	NO
136A	L 42	5	NO
137A	L 42	30	YES
92	L 43	CLEAN	NO
142	L 43	5	NO
143	L 43	10	NO
92A	L 43	CLEAN	NO
138	L 44	20	NO
139	L 44	10	NO
140	L 44	CLEAN	NO
146	L 44	10	NO
147	L 44	CLEAN	NO
138C	L 44	20	NO
121	L 47	CLEAN	NO
122	L 47	10	NO
123	L 47	CLEAN	NO

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
174	L 49	CLEAN	NO
176	L 49	CLEAN	NO
177	L 49	CLEAN	NO
178	L 49	40	YES
179	L 49	40	YES
188	L 49	18	NO
189	L 49	20	
190	L 49	40	YES
192	L 49	75	YES
206	L 49	10	NO
207	L 49	40	YES
8	L 50	10	NO
9	L 50	10	NO
10	L 50	80	YES
12	L 50	CLEAN	NO
16	L 50	5	NO
30	L 50	60	YES
31	L 50	10	NO
169	L 50	CLEAN	NO
170	L 50	CLEAN	NO
171	L 50	CLEAN	NO
172	L 50	CLEAN	NO
173	L 50	CLEAN	NO
184	L 50	5	NO
185	L 50	CLEAN	NO
214	L 50	CLEAN	NO
160	L 52	10	NO
161	L 52	CLEAN	NO
163	L 52	CLEAN	NO
164	L 52	CLEAN	NO
167	L 52	60	YES
168	L 52	CLEAN	NO
158	L 53	CLEAN	NO
159	L 53	5	NO
13	L 55	CLEAN	NO
23	L 55	80	YES

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
56	L 57	CLEAN	NO
57	L 57	CLEAN	NO
58	L 57	CLEAN	NO
59	L 57	CLEAN	NO
97	L 58	10	NO
98	L 58	CLEAN	NO
99	L 58	50	YES
100	L 58	50	YES
15	L 60	CLEAN	
204	L 61	5	NO
205	L 61	40	YES
205A	L 61	CLEAN	NO
187	L 62	40	YES
180	L 62	CLEAN WITH LOTS OF VEGETATION	NO
182	L 62	5	NO
183	L 62	CLEAN	NO
186	L 62	10	NO
180B	L 62	5	NO
156	L 63	CLEAN	NO
157	L 63	5	NO
20	L 64	30	YES
21	L 64	30	YES
20A	L 64	30	YES
155	L 65	CLEAN	NO
162	L 65	5	NO
165	L 65	5	NO
266	L 66	5	NO
267	L 66	5	NO
270	L 66	CLEAN	NO
269A	L 66	5	NO

WE SEE THINGS YOU CAN'T



17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
264	L 67	10	NO
265	L 67	CLEAN	NO
268	L 67	5	NO
269	L 67	5	NO
270A	L 67	CLEAN	NO
271	L 68	30	YES
272	L 68	5	NO
273	L 68	60	YES
274	L 68	CLEAN	NO
256	L 69	CLEAN	NO
259	L 69	25	YES
260	L 69	CLEAN	NO
262	L 69	CLEAN	NO
263	L 69	CLEAN	NO
275	L 70	35	YES
276	L 70	20	NO
274A	L 70	5	NO
277A	L 70	10	NO
258	L 71	CLEAN	NO
261	L 71	90	YES
248	L 72	5	NO
257	L 72	CLEAN	NO
247	L 73	10	NO
255	L 73	5	NO
277	L 74	5	NO
278	L 74	10	NO
252	L 76	5	NO
253	L 76	10	NO
249	L 78	CLEAN	NO
250	L 78	CLEAN	NO
251	L 78	CLEAN	NO

WE SEE THINGS YOU CAN'T

17891 Wetstone Rd.  
 North Ft. Myers, Fl. 33917  
 239-707-5034  
 Inspection Sheet

Storm Box	Lake	Condition (% Sand and Debris)	Recommend Cleaning
18	L B1		NO
19	L B1		NO
119	ROAD/Corso Meditarre Circle	50	YES
120	ROAD/Corso Meditarre Circle	30	YES
175	CA 20 A	30	YES
181	CA 19	5	NO
211	CA 8	CLEAN	NO
216	CA 8	CLEAN	NO
195	CA 20 A	65	YES

WE SEE THINGS YOU CAN'T



**M.R.I. UnderWater Specialists,Inc.**

**17891 Wetstone Rd  
North Ft. Myers, FL 33917  
239-707-5034 office  
239-236-1234 fax**

CGC 1507963



**Name**

Mediterra North & South CDD  
Cleo Crismond  
9220 Bonita Beach Rd  
suite 214  
Bonita Springs, Florida 34135

**Proposal**

**Project**

**Cleaning**

**Date**

5/3/2016

**Estimate #**

710

**Description**

Total Cost to Dive, Clean and Remove Sand and Debris from Lake interconnects, Curb inlets, as per our report.

28,300.00

**Total \$28300.00**

All material is guaranteed to be as specified. All work to be completed in a workmanlike manner according to standard practices. Additional charges may occur if any changes are made during scope of work and will become an extra charge over and above the estimate. All agreements contingent upon strikes, accidents or delays beyond our control. Owner to carry fire, tornado and other necessary insurance. Our workers are fully covered by workman's Compensation insurance. We will not be responsible for any unforeseen incidents, when we dewater any wet well system. Due to sink holes crevases or breeches etc. in and around wet well. This proposal does not include replacing any landscaping(Grass,trees, shrubs.etc.) all Jobsites will be left clean,

Authorized Signature \_\_\_\_\_

Mike Radford President

This proposal may be withdrawn if not accepted within 30 days.

Arreptaurr of Proposal The Above price, specifications and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payments will be made within 30 days after invoiced. If not we will agree to pay a 10% late fee.

This proposal may be withdrawn if not accepted within thirty (30) days.

Signature\_\_\_\_\_

Date of acceptance\_\_\_\_\_